

---

# 2025 Annual Drinking Water Quality Report

Martindale Water Supply Corporation • Phone: 512-357-6951

*We are pleased to present our annual Drinking Water Quality Report for the period ending December 31, 2025. This report is designed to inform you about the quality water and services we provide to you every day. We are excited to be delivering this annual report to you.*

## Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

This report is a summary of the quality of the water we provide our customers. The analysis was made using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in these pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

## Information on Sources of Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Martindale WSC purchases water from CRWA, the Hays/Caldwell WTP (Water Treatment Plant). This WTP provides surface water from the San Marcos River located in Caldwell County and Guadalupe River water from Guadalupe County via a pipeline. The Martindale WSC also utilizes local ground water under the influence of surface water provided by three wells located in Caldwell County.

## Information about Source Water Assessments

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information about your sources of water, please contact Steve Fonville or refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>. Further details about sources and sourcewater assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW/>. See page two for sample site locations.

## ALL Drinking Water May Contain Contaminants

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

## Information about Secondary Constituents

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

## SPECIAL NOTICE

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infections by Cryptosporidium are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Water Hotline or at <http://www.epa.gov/safewater/lead>.

## We Welcome Your Comments

If you have any questions about this report or any other issue concerning your water utility, please contact us at 512-357-6951.

## Public Participation Opportunities

DATE: 2nd Wednesday of each month TIME: 6:30 p.m.

LOCATION: 206 Main St./Water Supply Office

PHONE: 512-357-6951

WEB: [www.martindalewater.org](http://www.martindalewater.org)

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

## Source Water Assessment Sample Sites

Source Name	Type of Water	Report Status	Location
2 - Main Street / Johnson Street (GUI)	Ground water under direct influence of surface water	YES Operational	206 Main St. Martindale, TX
2 - Main Street / Johnson Street (GUI)	Ground water under direct influence of surface water	YES Operational	206 Main St. Martindale, TX
SW from CRWA Hays Caldwell WTP	Surface water	YES Operational	135 Martindale Rd San Marcos, TX
CC from TX0280024 CRWA Hays Caldwell WTP			

## En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. 512-357-6951-para hablar con una persona bilingue en español.

## Water Quality Test Results

**Definitions:** The following tables contain scientific terms and measures, some of which may require explanation.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Action Level Goal (ALG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

**Avg:** Regulatory compliance with some MCLs are based on running annual average of monthly samples.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Level 1 Assessment:** A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Level 2 Assessment:** A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E.coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Maximum residual disinfectant level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum residual disinfectant level goal (MRDLG):** The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**MFL:** million fibers per liter (a measure of asbestos)

**na:** not applicable

**mrem:** millirems per year (a measure of radiation absorbed by the body)

**NTU:** nephelometric turbidity units (a measure of turbidity)

**pCi/L:** picocuries per liter (a measure of radioactivity)

**ppb:** micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water

**ppm:** milligrams per liter or part per million - or one ounce in 7,350 gallons of water

**Treatment Technique or TT:** A required process intended to reduce the level of a contaminant in drinking water.

**Variations and Exemptions:** State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**RAA:** Running Annual Average

**LRAA:** Locational Running Annual Average

**pt:** parts per trillion, or nanograms per liter (ng/L)

**ppq:** parts per quadrillion, or picograms per liter (pg/L)

## DISINFECTANT RESIDUAL

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL/MRDLG Goal	Units	Violation	Source in Drinking Water
Chlorine	2025	1.35	0.36-3.01	4/4	ppm	N	Water additive used to control microbes.

## REGULATED CONTAMINANTS

In the tables below, we have shown the regulated contaminants that were detected. Chemical sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

### LEAD AND COPPER

Date Sampled	Contaminant	90th Percentile: 90% of your water utility	Range of Sampled Result (low-high)	Unit of measure	AL over AL	Sites	Typical source
2021-2023	COPPER, FREE	0.206	0	ppm	1.3	0	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
2021-2023	LEAD	0	0	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for thirty seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Disinfection Byproducts	Sample point	Period	Highest LRAA	Range	Unit	MCL	MCLO	Typical Source
TOTAL HALOACETIC ACIDS (HAAS)	122 ROOTS DR. MARTINDALE, TX	2025	11	5.3-10.4	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAAS)	JOHNSON/CROCKETT STS., MARTINDALE, TX	2025	18	1-39.9	ppb	60	0	By-product of drinking water disinfection
TTHM	122 ROOTS DR. MARTINDALE, TX	2025	36	11.7-33.9	ppb	80	0	By-product of drinking water disinfection
TTHM	JOHNSON/CROCKETT STS., MARTINDALE, TX	2025	48	2.3-111	ppb	80	0	By-product of drinking water disinfection

Regulated Contaminants	Collection Date Level	Highest	Range	Unit	MCL	MCLG	Typical Source
BARIUM	1/15/2025	0.0392	0.0392	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
DIBROMOCHLOROMETHANE	10/7/2025	44.3	1-44.3	UG/L	0	0.06	
FLUORIDE	1/15/2025	0.23	0.23	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL	1/15/2025	0.0021	0.0021	MG/L	0	0.1	
NITRATE	7/31/2025	6.9	0.89-6.9	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE-NITRITE	10/13/2021	1.7	1.7	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

## TURBIDITY

**INFORMATION STATEMENT:** Turbidity is a measure of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Percentage of samples in compliance with Std	Months occurred	Violation	Highest Single Measurement	Month occurred	Sources	Level indicator
100.00	12	NO	0.28	February	GUITP - MEMBRANE PLANT	Yes

## COLIFORM BACTERIA

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample	1		0	N	Naturally present in the environment.

## VIOLATIONS

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
12/1/2025-12/31/2025	TURBIDITY	MONITORING, ROUTINE (IESWTR/LT1), MAJOR	Failed to collect and/or report required turbidity samples or MCI
12/1/2025-12/31/2025	CHLORINE	MONITORING, RTN/RPT MAJOR (SWTR-FILTER)	Failed to collect and/or report required turbidity samples or MCI

The employee responsible for submission of these reports was out on medical leave during Dec. 2025 and Jan. 2026. The reports were submitted to the TCEQ in early Feb. 2026. The submittal was considered late.

Also attached to this report are analysis reports by the Texas Department of State Health from water samples taken in 2025 within the Martindale WSC system and the Hays/Caldwell Water Treatment Plant covering met-als, minerals, radioactive compounds, organic compounds, pesticides, and other contaminants. Please note that a "less than" (<) indicates a level below the detection limits of the lab instrument – the contaminant is non-detectable.

Martindale WSC has developed an inventory of both Corporation and customer owned service lines. To access this inventory please contact the office at 512-357-6951.

**The employees of the Martindale Water Supply Corporation work to provide top quality water to every household. We ask that all our customers help us protect our water sources.**

**Steven Fonville, General Manager, Martindale Water Supply Corp.**



**Texas Department of State  
Health Services**

**\*ALL MINERALS  
Analysis Report**

Submitter ID # (PWS ID #): 0280013

MARTINDALE WSC  
FORSSELL, JAMES  
PO BOX 175  
MARTINDALE, TX 78655-0175

Date Reported: 02/04/2025  
Report ID#: 202502040B2445AH10817

Lab Sample ID# AH10817      Water Source  
Sample Priority: NORMAL      Entry Point(s) EP001  
TCEQ Sample ID: 2518522

Date Collected: 01/15/2025 13:52  
Date Received: 01/16/2025

Sample Cond.: Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Field pH Result	8	pH			
Conductance @ 25.0 °C <sup>1</sup>	628	µmho/cm	SM 2510 B	01/17/2025 10:03	NP
Phenolphthalein Alkalinity as CaCO <sub>3</sub>	<10	mg/L	SM 2320B	01/17/2025 10:55	ME
* <u>Total Alkalinity as CaCO<sub>3</sub></u>	217	mg/L	SM 2320B	01/17/2025 10:55	ME
Bicarbonate	265	mg/L	SM 2320B	01/17/2025 10:55	ME
Carbonate	<10	mg/L	SM 2320B	01/17/2025 10:55	ME
Fluoride <sup>1</sup>	0.23	mg/L	EPA 300.0	01/16/2025 16:22	ME
Chloride <sup>1</sup>	38	mg/L	EPA 300.0	01/16/2025 16:22	ME
Sulfate <sup>1</sup>	30	mg/L	EPA 300.0	01/16/2025 16:22	ME
Total Dissolved Solids <sup>1</sup>	370	mg/L	SM 2540C	01/18/2025 11:49	DB
Nitrate as N <sup>1</sup>	4.75	mg/L	EPA 353.2	01/16/2025 15:51	AD

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(\*) meet all TNI (2016 Standard) requirements.

Authorized by Team Lead NPATEL on 01/30/2025

\* 12.7 GRAINS/GAL.

**Texas Department of State  
 Health Services**

**\*SINGLE MINERAL  
 Analysis Report**

Submitter ID # (PWS ID #): 0280013

MARTINDALE WSC  
 FORSELL, JAMES  
 PO BOX 175  
 MARTINDALE, TX 78655-0175

Date Reported : 02/04/2025  
 Report ID# : 20250204082445AH10830

Lab Sample ID# : AH10830      Water Source :  
 Sample Priority : NORMAL      Entry Point(s) : EP001  
 TCEQ Sample ID: 2528858

Date Collected : 01/15/2025 13:52  
 Date Received : 01/16/2025

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Total Cyanide <sup>1</sup>	< 0.01	mg/L	10-204-00-1-X	01/24/2025 11:39	ME

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2016 Standard) requirements.

Authorized by Team Lead NPATEL on 01/30/2025

Texas Department of State  
Health Services

**\*ALL METALS  
Analysis Report**

Submitter ID # (PWS ID #): 0280013

MARTINDALE WSC  
FORSSELL, JAMES  
PO BOX 175  
MARTINDALE, TX 78655-0175

Date Reported : 02/04/2025  
Report ID# : 20250204082445AH10843

Lab Sample ID# : AH10843      Water Source :  
Sample Priority : NORMAL      Entry Point(s) : EP001  
TCEQ Sample ID: 2516367

Date Collected : 01/15/2025 13:52  
Date Received : 01/16/2025

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	01/16/2025	DP
pH Check	Completed		EPA 200.2	01/17/2025	TH
Turbidity Screen	Completed		SM 2130B	01/17/2025	TH
Visible Particles	Completed			01/17/2025	TH
Total Hardness as CaCO3 by Calculation	259	mg/L	SM 2340B	01/24/2025	BF
Aluminum <sup>1</sup>	0.0896	mg/L	EPA 200.8	01/17/2025	DP
Antimony <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	01/17/2025	DP
Arsenic <sup>1</sup>	< 0.0020	mg/L	EPA 200.8	01/17/2025	DP
Barium <sup>1</sup>	0.0392	mg/L	EPA 200.8	01/17/2025	DP
Beryllium <sup>1</sup>	< 0.00080	mg/L	EPA 200.8	01/17/2025	DP
Cadmium <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	01/17/2025	DP
Calcium	80.7	mg/L	EPA 200.7	01/24/2025	BF
Chromium <sup>1</sup>	< 0.0100	mg/L	EPA 200.8	01/17/2025	DP
Copper <sup>1</sup>	0.0314	mg/L	EPA 200.8	01/17/2025	DP
Iron <sup>1</sup>	< 0.010	mg/L	EPA 200.7	01/24/2025	BF
Lead <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	01/17/2025	DP
Magnesium <sup>1</sup>	13.9	mg/L	EPA 200.7	01/24/2025	BF
Manganese <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	01/17/2025	DP
Mercury <sup>1</sup>	< 0.00040	mg/L	EPA 245.1	01/27/2025	BF
Nickel <sup>1</sup>	0.0021	mg/L	EPA 200.8	01/17/2025	DP
Potassium <sup>1</sup>	2.16	mg/L	EPA 200.7	01/24/2025	BF
Selenium <sup>1</sup>	< 0.0030	mg/L	EPA 200.8	01/17/2025	DP
Silver <sup>1</sup>	< 0.0100	mg/L	EPA 200.8	01/17/2025	DP
Sodium <sup>1</sup>	24.4	mg/L	EPA 200.7	01/24/2025	BF
Thallium <sup>1</sup>	< 0.00040	mg/L	EPA 200.8	01/17/2025	DP
Zinc <sup>1</sup>	< 0.0050	mg/L	EPA 200.8	01/17/2025	DP

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(<sup>1</sup>) meet all TNI (2016 Standard) requirements.

Authorized by Team Lead KLE on 01/30/2025

**Texas Department of State  
Health Services**

**Pesticides by Method 508.1  
Analysis Report**

Submitter ID # (PWS ID #): 0280013

MARTINDALE WSC  
FORSSELL, JAMES  
PO BOX 175  
MARTINDALE, TX 78655-0175

Date Reported: 02/13/2025  
Report ID#: 20250213083740AH11053

Lab Sample ID#: AH11053	Water Source	Date Collected: 01/15/2025 13:52	Conc. Units: ug/L
Sample Priority: NORMAL	Entry Point(s): EP001	Date Received: 01/16/2025	Method: 508.1 Rev. 2.0
TCEQ Sample ID: 2509621		Date Analyzed: 02/04/2025	Analyst: RM
			Sample Cond.: Acceptable

Regulated Compounds	Result	Qualifier
Chlordane <sup>1</sup>	<0.2	
Endrin <sup>1</sup>	<0.01	
Heptachlor epoxide <sup>1</sup>	<0.02	
Toxaphene <sup>1</sup>	<1.	
Screened Compounds	Result	Qualifier
Aroclor 1016 <sup>2</sup>	<0.08	
Aroclor 1221 <sup>2</sup>	<20.	
Aroclor 1232 <sup>2</sup>	<0.5	
Aroclor 1242 <sup>2</sup>	<0.3	
Aroclor 1248 <sup>2</sup>	<0.1	
Aroclor 1254 <sup>2</sup>	<0.1	
Aroclor 1260 <sup>2</sup>	<0.2	

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2016 Standard) requirements. The test results for analytes noted(2) meet all TNI (2016 Standard) requirements for Aroclor Identification. Aroclor quantitation is not accredited.

Authorized by Team Lead JME on 02/11/2025

**Volatile Organic Compounds by GC/MS  
Analysis Report**

**Texas Department of State  
Health Services**

Submitter ID # (PWS ID #): 0280013

MARTINDALE WSC  
FORSSELL, JAMES  
PO BOX 175  
MARTINDALE, TX 78655-0175

Date Reported: 01/28/2025  
Report ID#: 20250128083249AH10930

Lab Sample ID#: AH10930      Water Source: *206 MAIN ST.*      Date Collected: 01/15/2025 13:52      Conc. Units: µg/L  
Sample Priority: NORMAL      Entry Point(s): EP001      Date Received: 01/16/2025      Method: EPA 524.2  
TCEQ Sample ID: 2500726      Date Analyzed: 01/17/2025      Analyst: TB  
Sample Cond.: Acceptable

Regulated Cmpds.	Result	Qualifier	Monitored Cmpds	Result	Qualifier
Benzene <sup>1</sup>	<0.5		1,2,4-Trimethylbenzene	<1.0	
Carbon tetrachloride <sup>1</sup>	<0.5		1,2,3-Trichlorobenzene	<1.0	
Monochlorobenzene <sup>1</sup>	<0.5		n-Propylbenzene	<1.0	
o-Dichlorobenzene <sup>1</sup>	<0.5		n-Butylbenzene	<1.0	
para-Dichlorobenzene <sup>1</sup>	<0.5		Naphthalene	<1.0	
1,2-Dichloroethane <sup>1</sup>	<0.5		Hexachlorobutadiene	<1.0	
1,1-Dichloroethylene <sup>1</sup>	<0.5		1,3,5-Trimethylbenzene	<1.0	
cis-1,2-Dichloroethylene <sup>1</sup>	<0.5		4-Isopropyltoluene	<1.0	
trans-1,2-Dichloroethylene <sup>1</sup>	<0.5		Isopropylbenzene	<1.0	
1,2-Dichloropropane <sup>1</sup>	<0.5		t-Butylbenzene	<1.0	
Dichloromethane <sup>1</sup>	<0.5		s-Butylbenzene	<1.0	
Ethylbenzene <sup>1</sup>	<0.5		Trichlorofluoromethane	<2.0	
Styrene <sup>1</sup>	<0.5		Dichlorodifluoromethane	<2.0	
Tetrachloroethylene <sup>1</sup>	<0.5		Bromochloromethane	<1.0	
Toluene <sup>1</sup>	<0.5		<b>Other Compounds</b>	<b>Result</b>	<b>Qualifier</b>
1,2,4-Trichlorobenzene <sup>1</sup>	<0.5		Acetone	<10	
1,1,1-Trichloroethane <sup>1</sup>	<0.5		Acrylonitrile	<10	
1,1,2-Trichloroethane <sup>1</sup>	<0.5		2-Butanone (MEK)	<10	
Trichloroethylene <sup>1</sup>	<0.5		Carbon disulfide	<1.0	
Vinyl chloride <sup>1</sup>	<0.5		Ethyl methacrylate	<1.0	
Xylenes (total) <sup>1</sup>	<0.5		2-Hexanone	<1.0	
<b>Monitored Cmpds.</b>	<b>Result</b>	<b>Qualifier</b>	Iodomethane	<5.0	G
Chloroform	27		Methyl methacrylate	<1.0	
Bromodichloromethane	17		4-Methyl-2-pentanone (MIBK)	<2.0	
Dibromochloromethane	16		Methyl-t-butyl ether (MTBE)	<0.5	
Bromoform	12		Tetrahydrofuran	<5.0	
Dibromomethane	<1.0		<b>Comments:</b>		
1,3-Dichlorobenzene	<1.0		N - See sample comments.		
1,1-Dichloropropene	<1.0		X - The Minimum Reporting Limit (MRL) verification check did not meet the method acceptance limits.		
1,1-Dichloroethane	<1.0		G - CCV/LFB recovery was below method acceptance limits.		
1,1,2,2-Tetrachloroethane	<1.0		EPA Method 524.2 - CCV/LFB recovery of Chloromethane is above method acceptance criteria. Chloromethane was not detected in the sample. The test results on this report relate only to the sample identified on this report. The test results for analytes noted(*) meet all TNI (2016 Standard) requirements.		
1,3-Dichloropropane	<1.0				
Chloromethane	<2.0	NX			
Bromomethane	<2.0	G			
1,2,3-Trichloropropane	<1.0				
1,1,1,2-Tetrachloroethane	<1.0				
Chloroethane	<2.0				
2,2-Dichloropropane	<1.0				
2-Chlorotoluene	<1.0				
4-Chlorotoluene	<1.0				
Bromobenzene	<1.0				
cis-1,3-Dichloropropene	<1.0				
trans-1,3-Dichloropropene	<1.0				

Authorized by Team Lead CJONES on 01/27/2025

**Texas Department of State  
Health Services**

**Herbicides in Drinking Water  
Analysis Report**

Submitter ID # (PWS ID #): 0280013

MARTINDALE WSC  
FORSSELL, JAMES  
PO BOX 175  
MARTINDALE, TX 78655-0175

Date Reported : 02/13/2025  
Report ID# : 20250213083740AH11027

Lab Sample ID# : AH11027	Water Source	Date Collected : 01/15/2025 13:52	Conc. Units : µg/L
Sample Priority : NORMAL	Entry Point(s) : EP001	Date Received : 01/16/2025	Method : 515.4 Rev. 1.0
TCEQ Sample ID: 2522177		Date Analyzed : 01/24/2025	Analyst : LH
		Extraction Date : 01/22/2025	Sample Cond. : Acceptable

Regulated Compounds	Result	Qualifier
2,4-D <sup>1</sup>	<0.1	
2,4,5-TP (Silvex) <sup>1</sup>	<0.2	
Pentachlorophenol <sup>1</sup>	<0.04	
Dalapon <sup>1</sup>	<1	
Dinoseb <sup>1</sup>	<0.2	
Picloram <sup>1</sup>	<0.1	
Non Regulated Compounds	Result	Qualifier
Acifluorfen	<1.0	
Bentazon	<2.0	
Chloramben	<1.0	
2,4-DB	<2.0	
Dicamba	<1.0	
3,5-Dichlorobenzoic acid	<1.0	
Dichlorprop	<2.0	
Quindorac	<1.0	
2,4,5-T	<0.5	

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(<sup>1</sup>) meet all TNI (2016 Standard) requirements.

Authorized by Team Lead AMILLER on 02/12/2025

## Analytical Results

Client ID: ANTEA-PFOAS  
Lab ID: Q2515194001  
Sample ID: 2580378  
Project ID: PFAS PROJECT

Date Collected: 04/14/2025 10:20  
Date Received: 04/14/2025 14:07  
Location:  
Facility: EP001  
Sample Point: TRT-TAP

Matrix: Drinking Water  
Sample Type: SAMPLE

### Perfluorinated Alkyl Acids (E533 Perfluor Alkyl Acid)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
PFBA (CAS 375-22-4)	<0.00456	ug/L	0.00456	0.00456		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFMPA (CAS 377-73-1)	<0.00365	ug/L	0.00365	0.00365		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFPeA (CAS 2706-90-3)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFBS (CAS 375-73-5)	0.00322	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFMBA (CAS 863090-89-5)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFEESA (CAS 113507-82-7)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
NFDHA (CAS 151772-58-6)	<0.0183	ug/L	0.0183	0.0183		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
4:2FTS (CAS 757124-72-4)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFHxA (CAS 307-24-4)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFPeS (CAS 2706-91-4)	<0.00365	ug/L	0.00365	0.00365		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
HFPO-DA (CAS 13252-13-6)	<0.00456	ug/L	0.00456	0.00456		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFHpA (CAS 375-85-9)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFHxS (CAS 355-46-4)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
ADONA (CAS 919005-14-4)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
6:2FTS (CAS 27619-97-2)	<0.00365	ug/L	0.00365	0.00365		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFOA (CAS 335-67-1)	<0.00365	ug/L	0.00365	0.00183		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFHpS (CAS 375-92-8)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFNA (CAS 375-95-1)	<0.00365	ug/L	0.00365	0.00365		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFOS (CAS 1763-23-1)	0.00391	ug/L	0.00365	0.00183		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
9Cl-PF3ONS (CAS 756426-58-1)	<0.00183	ug/L	0.00183	0.00183		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
8:2FTS (CAS 39108-34-4)	<0.00456	ug/L	0.00456	0.00456		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFDA (CAS 335-76-2)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFUnA (CAS 2058-94-8)	<0.00183	ug/L	0.00183	0.00183		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
11Cl-PF3ONS (CAS 763051-92-9)	<0.00456	ug/L	0.00456	0.00456		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N
PFDoA (CAS 307-55-1)	<0.00274	ug/L	0.00274	0.00274		1	04/30/2025 08:13	KMK	05/07/2025 09:23	KRD	N

(PPT)

(PPB)

4 PARTS/TRILLION = 0.004 PARTS PER BILLION

## Analytical Results

Client ID: ANTEA-PFOAS      Date Collected: 04/14/2025 10:20      Matrix: Drinking Water  
Lab ID: Q2515194002      Date Received: 04/14/2025 14:07      Sample Type: FB  
Sample ID: 2580378FB      Location:  
Project ID: PFAS PROJECT      Facility: EP001  
Sample Point: TRT-TAP

### Perfluorinated Alkyl Acids (E533 Perfluor Alkyl Acid)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
PFBA (CAS 375-22-4)	<0.00463	ug/L	0.00463	0.00463		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFMPA (CAS 377-73-1)	<0.00370	ug/L	0.00370	0.00370		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFPeA (CAS 2706-90-3)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFBS (CAS 375-73-5)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFMBA (CAS 863090-89-5)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFEESA (CAS 113507-82-7)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
NFDHA (CAS 151772-58-6)	<0.0185	ug/L	0.0185	0.0185		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
4:2FTS (CAS 757124-72-4)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFHxA (CAS 307-24-4)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFPeS (CAS 2706-91-4)	<0.00370	ug/L	0.00370	0.00370		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
HFPO-DA (CAS 13252-13-6)	<0.00463	ug/L	0.00463	0.00463		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFHpA (CAS 375-85-9)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFHxS (CAS 355-46-4)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
ADONA (CAS 919005-14-4)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
6:2FTS (CAS 27619-97-2)	<0.00370	ug/L	0.00370	0.00370		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFOA (CAS 335-67-1)	<0.00370	ug/L	0.00370	0.00185		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFHpS (CAS 375-92-8)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFNA (CAS 375-95-1)	<0.00370	ug/L	0.00370	0.00370		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFOS (CAS 1763-23-1)	<0.00370	ug/L	0.00370	0.00185		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
9Cl-PF3ONS (CAS 756426-58-1)	<0.00185	ug/L	0.00185	0.00185		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
8:2FTS (CAS 39108-34-4)	<0.00463	ug/L	0.00463	0.00463		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFDA (CAS 335-76-2)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFUnA (CAS 2058-94-8)	<0.00185	ug/L	0.00185	0.00185		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
11Cl-PF3OUdS (CAS 763051-92-9)	<0.00463	ug/L	0.00463	0.00463		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H
PFDoA (CAS 307-55-1)	<0.00278	ug/L	0.00278	0.00278		1	05/15/2025 07:52	KMK	05/18/2025 01:02	KRD	N,H

### Analytical Results

<b>Client ID:</b> ANTEA-PFOAS	<b>Date Collected:</b> 04/14/2025 10:20	<b>Matrix:</b> Drinking Water
<b>Lab ID:</b> Q2515194003	<b>Date Received:</b> 04/14/2025 14:07	<b>Sample Type:</b> SAMPLE
<b>Sample ID:</b> 2580380	<b>Location:</b>	
<b>Project ID:</b> PFAS PROJECT	<b>Facility:</b> EP001	
	<b>Sample Point:</b> TRT-TAP	

#### Perfluorinated Alkyl Acids (E537 Perfluor Alkyl Acid FULL/E537.1 Perfluorinated UCMF)

Parameter	Results	Units	MRL	LOD	MCL	DF	Prepared	By	Analyzed	By	Qualifier
NMeFOSAA (CAS 2355-31-9)	<0.00560	ug/L	0.00560	0.00560		1	04/28/2025 10:26	APP	05/02/2025 15:18	KRD	N
NEiFOSAA (CAS 2891-50-5)	<0.00467	ug/L	0.00467	0.00467		1	04/28/2025 10:26	APP	05/02/2025 15:18	KRD	N
PFTTrDa (CAS 72629-94-8)	<0.00654	ug/L	0.00654	0.00654		1	04/28/2025 10:26	APP	05/02/2025 15:18	KRD	N
PFTaDA (CAS 378-06-7)	<0.00747	ug/L	0.00747	0.00747		1	04/28/2025 10:26	APP	05/02/2025 15:18	KRD	N

#### Surrogates

Parameter	Units	% Spike Recovery	Control Limits %	Qualifier
13C3-HFPO-DA (S)	%	92.3	70 - 130	
13C-PFDA (S)	%	101.0	70 - 130	
13C-PFHxA (S)	%	97.9	70 - 130	
d5-N-EiFOSAA (S)	%	102.0	70 - 130	



**Hays Caldwell**  
**Water Treatment Plant**  
**2025 Consumer Confidence Report**  
**PWS ID No. TX0280024**

Canyon Regional Water Authority is pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

This report is intended to provide you with important information about your drinking water and efforts made by the water system to provide safe drinking water. This Annual Water Quality Report is for the period of [\*January 1 to December 31, 2025\*](#).

Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (830)609-0543.

### ***Sources***

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

***Microbial Contaminants***, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

***Inorganic contaminants***, such as salts and metals, can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

***Pesticides and Herbicides***, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

***Organic Chemical Contaminants***, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

***Radioactive Contaminants***, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information

on taste, odor, or color of drinking water, please contact Canyon Regional Water Authority (830) 609-0543.

**You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800) 426-4791.**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:

<https://tceq.maps.arcgis.com/apps/webappviewer/index.html?id=217028ea4a01485f87db4d22aec72755>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <https://dww2.tceq.texas.gov/DWW/>.

Canyon Regional Water Authority Hays Caldwell Water Treatment Plant is Surface Water.

		Type of Water	Report Status	Location
SAN MARCOS RIVER	SAN MARCOS	SW	Operational	135 Martindale Rd. San Marcos, TX 78666
FROM GBRA	LAKE DUNLAP	SW	Operational	Lake Dunlap New Braunfels, TX

## **Water Quality Test Results**

The following tables contain scientific terms and measures, some of which may require explanation.

### **Definitions:**

**Action Level (AL)**– the concentration of a contaminant that if exceeded, triggers treatment or other requirements that a water system must follow.

**Avg-** Average; Regulatory compliance with some MCLs are based on running annual average of monthly samples.

**Level 1 assessment** – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria were found.

**Level 2 assessment** – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an Escherichia coli (E. coli) maximum contaminant level (MCL) violation has occurred and/or why total coliform bacteria were found on multiple occasions.

**Maximum Contaminant Level (MCL)** – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to maximum contaminant level goals as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level or MRDL** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal or MRDLG** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Minimum Reporting Limit or MRL** – Samples above the MRL are to be reported on the CCR.

**Treatment Technique (TT)** – A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**MFL** – million fibers per liter (a measure of asbestos).

**Mrem/year** – millirems per year (measure of radiation absorbed by the body).

**N/A** – Non Applicable

**ND** – Non-Detects; laboratory analysis indicates that the constituent is not present.

**NTU** – nephelometric turbidity units (a measure of turbidity).

**pCi/L** – picocuries per liter (a measure of radioactivity).

**ppb** – parts per billion, or micrograms per liter (**µg/L**).

**ppm** – parts per million, or milligrams per liter (**mg/L**).

**ppq** – parts per quadrillion, or picograms per liter (**pg/L**).

**ppt** – parts per trillion, or nanograms per liter (**ng/L**).

## Table of Contaminants

<b>TEST RESULTS</b>								
Results in the following tables contain data from January 1, 2023–December 31, 2024, otherwise data presented is from the most recent testing done in accordance with regulations.								
Contaminant	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation Yes(Y)/No(N)	Likely Source of Contamination
<b>Microbiological Contaminants</b>								
<b>Total Coliform Bacteria</b>  Sample schedule: Monthly	2025	<b>Absent</b>	N/A	0	MCL: (systems that collect 40 or more samples per month) 5% of monthly samples are positive. (Systems that collect <40 samples/month – 1 positive monthly sample.	N/A	<b>N</b>	Naturally present in the environment
<b>Fecal coliform and <i>E.coli</i></b>  Sample schedule: Monthly	2025	<b>Absent</b>	N/A	0	0	N/A	<b>N</b>	Human and animal fecal waste
<b>TOC</b>  Sample schedule: Monthly	2025	<b>3.05</b>	.92 – 3.05	N/A	TT	Mg/L	<b>N</b>	Naturally present in the environment
The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.								

Turbidity	Level Detected	Limit (Treatment Technique)	Violation for Year 2025	Likely Source of Contamination
Sample schedule: Daily				
<b>Highest Single Measurement</b>	0.09 NTU	1 NTU	N	Soil runoff, Bacteria, organic material, suspended particles
<b>Lowest Monthly % Meeting Limit</b>	100%	0.3 NTU	N	Soil runoff, Bacteria, organic material, suspended particles

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Contaminant	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation Yes(Y)/No(N)	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
<b>Beta/photon emitters</b>  Sample Schedule: Every 6 years. Next sample is 2027	2021	< 4	N/A	0	4	pCi/L	N	Decay of natural and man-made Deposits
<b>Alpha emitters</b>  Sample schedule: Every 6 years. Next sample is 2027	2021	< 3	N/A	0	15	pCi/L	N	Erosion of natural deposits
<b>Radium-228</b>  Sample schedule: Every 6 years. Next sample is 2027	2021	< 1	N/A	0	5	pCi/L	N	Erosion of natural Deposits
<b>Uranium</b>  Sample schedule: Every 6 years. Next sample is 2027	2021	< 0.001	0.001 – 30	0	30	ppb	N	Erosion of natural Deposits
<b>Inorganic Contaminants</b>								
<b>Aluminum</b>  Sample schedule: Yearly	2025	0.259	0.050 – 0.259	N/A	N/A	Ppb	N	Used as a coagulant in the water treatment process
<b>Antimony</b>  Sample schedule: Yearly	2025	< 0.001	0.001 – 6	6	6	Ppb	N	Discharge from petroleum refineries, fire retardants, ceramics, electronics, solder
<b>Arsenic</b>  Sample schedule: Yearly	2025	< 0.002	0.001 – 0.010	N/A	10	Mg/L	N	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
<b>Asbestos</b>  Sample schedule: Every 9 years. Next sample is 2031	2022	< 0.197	N/A	7	7	MFL	N	Decay of asbestos cement water mains; erosion of natural deposits

<b>Barium</b> Sample schedule: Yearly	2025	<b>0.036</b>	0.000 – 2.0	2	2	Mg/L	<b>N</b>	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
<b>Beryllium</b> Sample schedule: Yearly	2025	<b>&lt;0.001</b>	0.001 - 4	4	4	Ppb	<b>N</b>	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
<b>Cadmium</b> Sample schedule: Yearly	2025	<b>&lt;0.001</b>	0.001 - 5	5	5	Ppb	<b>N</b>	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
<b>Chromium</b> Sample schedule: Yearly	2025	<b>&lt;0.01</b>	0.001 – 0.10	100	100	Mg/L	<b>N</b>	Discharge from steel and pulp mills; erosion of natural deposits
<b>Copper / Texas</b> Sample schedule: Yearly	2025	<b>0.004</b>	0.00 – 1.3	1.3	AL=1.3 (EPA National Primary Drinking Water Regulations)	Mg/L	<b>N</b>	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
<b>Cyanide</b> Sample schedule: Yearly	2025	<b>&lt;0.01</b>	0.01 - 200	200	200	Mg/L	<b>N</b>	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
<b>Fluoride</b> Sample schedule: Yearly	2025	<b>0.2</b>	0.1 - 4	4	4	Mg/L	<b>N</b>	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
<b>Lead / Texas</b> Sample schedule: Yearly	2025	<b>&lt;0.001</b>	<0.001 - 15	0	AL=15	Ppb	<b>N</b>	Corrosion of household plumbing systems, erosion of natural deposits
<b>Mercury (inorganic)</b> Sample schedule: Yearly	2025	<b>&lt; 0</b>	0 - 2	2	2	Ppb	<b>N</b>	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
<b>Nitrate (as Nitrogen)</b> Sample schedule: Yearly	2025	<b>1.83</b>	0.1 - 10	10	10	Mg/L	<b>N</b>	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

<b>Nitrite (as Nitrogen)</b>  Sample schedule: Every 9 years. Next sample is 2031	2022	< 0.05	0.05 - 1	1	1	Mg/L	N	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Selenium</b>  Sample schedule: Yearly	2025	< 0.003	0.001 - 50	50	50	Mg/L	N	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<b>Thallium</b>  Sample schedule: Yearly	2025	< 0	0 - 2	0.5	2	Mg/L	N	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
<p><b>*Lead and Copper Rule Testing</b>  <i>The 1994 Federal Lead &amp; Copper Rule mandates a household testing program for these substances. According to the rule, 90% of samples from high-risk homes must have levels less than 0.015 milligrams per liter for lead and 1.3 milligrams per liter for copper.</i></p>								
<b>Synthetic Organic Contaminants Including Pesticides and Herbicides</b>								
<b>2, 4, -D</b>  Sample schedule: Yearly	2025	< 0.1	0.1 - 70	70	70	Ppb	N	Runoff from herbicide used on row crops
<b>2, 4, 5-TP(Silvex)</b>  Sample schedule: Yearly	2025	< 0.2	0.2 - 50	50	50	Ppb	N	Residue of banned herbicide
<b>Alachlor</b>  Sample schedule: Yearly	2025	< 0.2	0 - 2	0	2	Ppb	N	Runoff from herbicide used on row crops
<b>Atrazine</b>  Sample schedule: Yearly	2025	< 0.1	0.1 - 3	3	3	Ppb	N	Runoff from herbicide used on row crops
<b>Benzo(a)pyrene (PAH)</b>  Sample schedule: Yearly	2025	< 0.02	0 - 0.2	0	0.2	Ppb	N	Leaching from linings of water storage tanks and distribution lines
<b>Carbofuran</b>  Sample schedule: Yearly	2025	< 0.9	0 - 40	40	40	Ppb	N	Leaching of soil fumigant used on rice and alfalfa
<b>Chlordane</b>  Sample schedule: Yearly	2025	< 0.2	0.2 - 2	0	2	Ppb	N	Residue of banned termiticide
<b>Dalapon</b>  Sample schedule: Yearly	2025	< 1	1 - 200	200	200	Ppb	N	Runoff from herbicide used on rights of way

<b>Di(2-ethylhexyl) adipate</b> Sample schedule: Yearly	2025	<0.6	0.6 - 400	400	400	Ppb	N	Discharge from chemical factories
<b>Di(2-ethylhexyl) phthalate</b> Sample schedule: Yearly	2025	<0.6	0.6 - 6	0	6	Ppb	N	Discharge from rubber and chemical factories
<b>1, 2-Dibromo-3-chloropropane</b> Sample schedule: Yearly	2025	<0.02	0.02 – 0.2	0	0.2	Ppb	N	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards
<b>Dinoseb</b> Sample schedule: Yearly	2025	<0.2	0.2 - 7	7	7	Ppb	N	Runoff from herbicide used on soybeans and vegetables
<b>Endrin</b> Sample schedule: Yearly	2025	<0.01	0.01 - 2	2	2	Ppb	N	Residue of banned insecticide
<b>Ethylene dibromide</b> Sample schedule: Yearly	2025	<0.01	0.01 – 0.5	0	0.5	Ppb	N	Discharge from petroleum refineries
<b>Heptachlor</b> Sample schedule: Yearly	2025	<0.04	0.04 – 0.4	0	0.4	Ppb	N	Residue of banned termiticide
<b>Heptachlor epoxide</b> Sample schedule: Yearly	2025	<0.02	0.02 – 0.2	0	0.2	Ppb	N	Breakdown of heptachlor
<b>Hexachlorobenzene</b> Sample schedule: Yearly	2025	<0.1	0.1 - 1	0	1	Ppb	N	Discharge from metal refineries and agricultural chemical factories
<b>Hexachlorocyclopentadiene</b> Sample schedule: Yearly	2025	<0.1	0.1 - 50	50	50	Ppb	N	Discharge from chemical factories
<b>Methoxychlor</b> Sample schedule: Yearly	2025	<0.1	0.1 - 40	40	40	Ppb	N	Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock
<b>Oxamyl [Vydate]</b> Sample schedule: Yearly	2025	< 2	2 - 200	200	200	Ppb	N	Runoff from landfills of waste chemicals

<b>Pentachlorophenol</b> Sample schedule: Yearly	2025	<0.04	0.04 - 1	0	1	Ppb	N	Discharge from wood preservative factories
<b>Picloram</b> Sample schedule: Yearly	2025	<0.1	0.1 - 500	500	500	Ppb	N	Herbicide runoff
<b>Simazine</b> Sample schedule: Yearly	2025	<0.07	0.07 - 4	4	4	Ppb	N	Herbicide runoff
<b>Toxaphene</b> Sample schedule: Yearly	2025	< 1	1 - 3	0	3	Ppb	N	Runoff/leaching from insecticide used on cotton and cattle
<b>Volatile Organic Contaminants</b>								
<b>Benzene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 5	0	5	Ppb	N	Discharge from factories; leaching from gas storage tanks and landfills
<b>Carbon tetrachloride</b> Sample schedule: Yearly	2025	<0.5	0.1 - 5	0	5	Ppb	N	Discharge from chemical plants and other industrial activities
<b>Chlorobenzene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 100	100	100	Ppb	N	Discharge from chemical and agricultural chemical factories
<b>Chlorite</b> Sample schedule: Yearly	2025	0.86	0-0.800	0.8	1.0	Mg/L	N	By-product of drinking water chlorination
<b>o-Dichlorobenzene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 600	600	600	Ppb	N	Discharge from industrial chemical factories
<b>p-Dichlorobenzene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 75	75	75	Ppb	N	Discharge from industrial chemical factories
<b>1,2-Dichloroethane</b> Sample schedule: Yearly	2025	<0.5	0.5 - 5	0	5	Ppb	N	Discharge from industrial chemical factories

<b>1,1 – Dichloroethylene</b> Sample schedule: Yearly	2025	< 1	1 - 7	7	7	Ppb	N	Discharge from industrial chemical factories
<b>Cis-1,2- Dichloroethylene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 70	70	70	Ppb	N	Discharge from industrial chemical factories
<b>Trans – 1,2 – Dichloroethylene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 100	100	100	Ppb	N	Discharge from industrial chemical factories
<b>Dichloromethane</b> Sample schedule: Yearly	2025	<0.5	0.5 - 5	0	5	Ppb	N	Discharge from pharmaceutical and chemical factories
<b>1,2- Dichloropropane</b> Sample schedule: Yearly	2025	<0.5	0.5 - 5	0	5	Ppb	N	Discharge from industrial chemical factories
<b>Ethylbenzene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 700	700	700	Ppb	N	Discharge from petroleum refineries
<b>Haloacetic Acids (HAA5)<sup>1</sup></b> Sample schedule: Quarterly	2025	43.0	0 -71.7	N/A	60	Ppb	N	By-product of disinfection
<b>Styrene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 100	100	100	Ppb	N	Discharge from rubber and plastic factories; leaching from landfills
<b>Tetrachloroethylene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 5	0	5	Ppb	N	Leaching from PVC pipes; discharge from factories and dry cleaners
<b>1,2,4- Trichlorobenzene</b> Sample schedule: Yearly	2025	< 1	0 - 70	70	70	Ppb	N	Discharge from textile-finishing factories
<b>1,1,1 – Trichloroethane</b> Sample schedule: Yearly	2025	<0.5	0.5 - 200	200	200	Ppb	N	Discharge from metal degreasing sites and other factories
<b>1,1,2 – Trichloroethane</b> Sample schedule: Yearly	2025	<0.5	0.5 - 5	3	5	Ppb	N	Discharge from industrial chemical factories

<b>Trichloroethylene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 5	0	5	Ppb	N	Discharge from metal degreasing sites and other factories
<b>TTHM [Total trihalomethanes]</b> <sup>2</sup> Sample schedule: Quarterly	2025	63.9	1 - 80	N/A	80	Ppb	N	By-product of drinking water chlorination
<b>Toluene</b> Sample schedule: Yearly	2025	<0.5	0.5 - 1	1	1	Mg/L	N	Discharge from petroleum factories
<b>Vinyl Chloride</b> Sample schedule: Yearly	2025	<0.5	0.5 - 2	0	2	Ppb	N	Leaching from PVC piping; discharge from plastics factories
<b>Xylenes</b> Sample schedule: Yearly	2025	<0.5	0.5 - 10	10	10	Mg/L	N	Discharge from petroleum factories; discharge from chemical factories
<sup>1</sup> The value in the Highest Level Detected column is the highest average of all HAA5 sample results collected at a location over a year. <sup>2</sup> The value in the Highest Level Detected column is the highest average of all TTHM sample results collected at a location over a year.								

Disinfectant Residual	Year	Average Level	Range of Disinfectant Levels	MRDLG	MRDL	Units	Violation Yes(Y)/ No(N)	Likely Source of Contamination
<b>Chlorine</b> Sample schedule: Daily	2025	2.10	1.20 - 2.50	4	4	Mg/L	N	Water additive used to control microbes
<b>Chlorine Dioxide</b> Sample schedule: Daily	2025	0	1 - 10	0.8	0.8	Mg/L	N	Water additive used to control microbes

## UCMR<sub>5</sub>

### PFAS

PFAS stands for **per-** and **polyfluoroalkyl** substances, which are a group of chemicals used to make products that resist heat, oil, stains, grease, and water. PFAS has a strong carbon-fluorine bond that makes them persistent in the environment and in the bodies of animals and people, posing health risks.

Hays Caldwell WTP was selected as a UCMR 5 (Fifth Unregulated Contaminant Monitoring Rule) sample sight for PFAS. Please see the table below for the samples taken in 2023. There was two samples over the MRL.

Additionally, any Public Water System with a sample above the Minimum Reporting Level (MRL) is required to report this on their CCR (it is per sample, not a running annual average).

Please follow the link below to EPA's UCMR 5 website for more information.

<https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule#qanda>

Parameter Name	Collection Date	Parameter Abbreviation	Reporting Limit (ng/L)	EP001/Results (ng/L)
Perfluorobutanoic acid	2023	PFBA	5.02	ND
Perfluoro-3-methoxypropanoic acid	2023	PFMPA	4.02	ND
<b>Perfluoropentanoic acid</b>	<b>2023</b>	<b>PFPeA</b>	<b>3.01</b>	<b>3.20</b>
<b>Perfluorobutanesulfonic acid</b>	<b>2023</b>	<b>PFBS</b>	<b>3.01</b>	<b>3.14</b>
Perfluoro-4-methoxybutanoic acid	2023	PFMBA	3.01	ND
Perfluoro(2-ethoxyethane)sulfonic acid	2023	PFEESA	3.01	ND
Nonafluoro-3,6-dioxaheptanoic acid	2023	NFDHA	20.1	ND
1H,1H,2H,2H-Perfluorohexane sulfonic acid	2023	4:2FTS	3.01	ND
Perfluorohexanoic acid	2023	PFHxA	3.01	ND
Perfluoropentanesulfonic acid	2023	PFPeS	4.02	ND
Hexafluoropropylene oxide dimer acid	2023	HFPO-DA	5.02	ND
Perfluoroheptanoic acid	2023	PFHpA	3.01	ND
Perfluorohexanesulfonic acid	2023	PFHxS	3.01	ND
4,8-Dioxa-3H-perfluorononanoic acid	2023	ADONA	3.01	ND
1H,1H,2H,2H-Perfluorooctane sulfonic acid	2023	6:2FTS	4.02	ND
Perfluorooctanoic acid	2023	PFOA	4.02	ND
Perfluoroheptanesulfonic acid	2023	PFHpS	3.01	ND
Perfluorononanoic acid	2023	PFNA	4.02	ND
Perfluorooctanesulfonic acid	2023	PFOS	4.02	ND
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	2023	9Cl-PF3ONS	2.01	ND
1H,1H,2H,2H-Perfluorodecane sulfonic acid	2023	8:2FTS	5.02	ND
Perfluorodecanoic acid	2023	PFDA	3.01	ND
Perfluoroundecanoic acid	2023	PFUnA	2.01	ND
11-Chloroelcosafluoro-3-oxaundecane-1-sulfonic acid	2023	11Cl-PF3OUdS	5.02	ND
Perfluorododecanoic acid	2023	PFDoA	3.01	ND
N-methyl perfluorooctanesulfonamidoacetic acid	2023	NMeFPSAA	6.18	ND
N-ethyl perfluorooctanesulfonamidoacetic acid	2023	NEtFOSAA	5.15	ND
Perfluorotridecanoic acid	2023	PFTrDA	7.21	ND
Perfluorotetradecanoic acid	2023	PFTeDA	8.24	ND

## Lead Service Line Inventory

CRWA service lines do not contain lead. Please contact CRWA to obtain a copy of the Lead Service Line Inventory.

## **Health Effects**

Maximum Contaminant Levels (MCL's) are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have one-in-a-million chance of having the described health effect.

### ***Microbiological Contaminants:***

***Total Coliform*** – Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. If Coliforms were found in more samples than allowed, this then is a warning of potential problems.

***Fecal coliform/E.Coli*** – Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.

***Turbidity*** – Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

***Total Organic Carbon*** – Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

### ***Radioactive Contaminants:***

***Beta/photon emitter*** – Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.

***Alpha emitters*** – Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

***Combined Radium 226/228*** – Some people who drink water that contains radium 226 or 228 in excess of the MCL over many years have an increased risk of getting cancer.

### ***Inorganic Contaminants:***

***Antimony*** – Some people who drink water that contains antimony well in excess of the MCL over many years could experience increased in blood cholesterol and decrease in blood sugar.

**Arsenic** – Some people who drink water that contains arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

**Asbestos** – Some people who drink water that contains asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.

**Barium** – Some people who drink water that contains barium in excess of the MCL over many years could experience an increase in their blood pressure.

**Beryllium** – Some people who drink water that contains beryllium well in excess of the MCL over many years could develop intestinal lesions.

**Cadmium** – Some people who drink water that contains cadmium in excess of the MCL over many years could experience kidney damage.

**Chromium** – Some people who use water that contains chromium well in excess of the MCL over many years could experience allergic dermatitis.

**Copper** – Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water that contains copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

**Cyanide** – Some people who drink water that contains cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.

**Fluoride** – Some people who drink water that contains fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.

**Lead** – Infants and children who drink water that contains lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

---

### ***Additional Health Information:***

**Lead** – If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Canyon Regional Water Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Mercury** – Some people who drink water containing mercury well in excess of the MCL over many years could experience kidney damage.

**Nitrate** – Infants below the age of six months who drink water that contains nitrate in excess of the MCL could become seriously ill and if untreated could die. Symptoms include shortness of breath and blue-baby syndrome.

**Nitrite** – Infants below the age of six months who drink water that contains nitrite in excess of the MCL could become seriously ill and, if untreated could die. Symptoms include shortness of breath and blue-baby syndrome.

**Selenium** – Selenium is an essential nutrient. However, some people who drink water-containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in fingers or toes, or problems with their circulation.

**Thallium** – Some people who drink water that contains thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.

### ***Synthetic organic contaminants including pesticides and herbicides.***

**2, 4-D** – Some people who drink water that contains the weed killer 2, 4-D well in excess of the MCL over many years could experience problems with their kidneys, liver, or adrenal glands.

**2, 4, 5-TP (Silvex)** – Some people who drink water that contains silvex in excess of the MCL over many years could experience liver problems.

**Acrylamide** – Some people who drink water containing high levels of acrylamide over a long period of time could have problems with their nervous system or blood, and may have an increased risk of getting cancer.

**Alachlor** – Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.

**Atrazine** – Some people who drink water that contains atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.

**Benzo(a)pyrene [PAH]** – Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.

**Carbofuran** – Some people who drink water that contains carbofuran in excess of the MCL over many years could experience problems with their blood, nervous, or reproductive system.

**Chlordane** – Some people who drink water that contains chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.

**Dalapon** – Some people who drink water that contains dalapon well in excess of the MCL over many years could experience minor kidney changes.

**Di (2-ethylhexyl) adipate** – Some people who drink water that contains di (2-ethylhexyl) adipate well in excess of the MCL over many years could experience general toxic effects or reproductive difficulties.

***Di (2-ethylhexyl) phthalate*** – Some people who drink water that contains di (2-ethylhexyl) phthalate in excess of the MCL over many years may have problems with their liver, or experience reproductive difficulties, and may have an increased risk of getting cancer.

***Dibromochloropropane (DBCP/1, 2-Dibromo-3-chloropropane)*** – Some people who drink water that contains DBCP in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.

***Dinoseb*** – Some people who drink water that contains dinoseb well in excess of the MCL over many years could experience reproductive difficulties.

***Dioxin (2,3,7,8-TCDD)*** – Some people who drink water that contains dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.

***Diquat*** – Some people who drink water that contains diquat in excess of the MCL over many years could get cataracts.

***Endothall*** – Some people who drink water that contains endothall in excess of the MCL over many years could experience problems with their stomach or intestines.

***Endrin*** – Some people who drink water that contains endrin in excess of the MCL over many years could experience liver problems.

***Epichlorohydrin*** – Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.

***Ethylene dibromide*** – Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer.

***Glyphosate*** – Some people who drink water that contains glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.

***Heptachlor*** – Some people who drink water that contains heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.

***Heptachlor epoxide*** – Some people who drink water that contains heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.

***Hexachlorobenzene*** – Some people who drink water that contains hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects, and may have an increased risk of getting cancer.

***Hexachlorocyclopentadiene*** – Some people who drink water that contains hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.

***Lindane*** – Some people who drink water that contains lindane in excess of the MCL over many years could experience problems with their kidneys or liver.

***Methoxychlor*** – Some people who drink water that contains methoxychlor in excess of the MCL over many years could experience reproductive difficulties.

***Oxamyl [Vydate]*** – Some people who drink water that contains oxamyl in excess of the MCL over many years could experience slight nervous system effects.

**PCBs [Polychlorinated byphenyls]** – Some people who drink water that contains PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.

**Pentachlorophenol** – Some people who drink water that contains pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.

**Picloram** – Some people who drink water that contains picloram in excess of the MCL over many years could experience problems with their liver.

**Simazine** – Some people who drink water that contains simazine in excess of the MCL over many years could experience problems with their blood.

**Toxaphene** – Some people who drink water that contains toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.

### **Volatile Organic Contaminants:**

**Benzene** – Some people who drink water that contains benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.

**Bromate** – Some people who drink water that contains bromate in excess of the MCL over many years may have an increased risk of getting cancer.

**Carbon Tetrachloride** – Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.

**Chloramines** – Some people who use water that contains chloramines well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water that contains chloramines well in excess of the MRDL could experience stomach discomfort or anemia.

**Chlorine** – Some people who use water that contains chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water that contains chlorine well in excess of the MRDL could experience stomach discomfort.

**Chlorite** – Some infants and young children who drink water that contains chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water that contains chlorite in excess of the MCL. Some people may experience anemia.

**Chlorine dioxide** – Some infants and young children who drink water that contains chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water that contains chlorine dioxide in excess of the MRDL. Some people may experience anemia.

**Chlorobenzene** – Some people who drink water that contains chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.

**o-Dichlorobenzene** – Some people who drink water that contains o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.

***p-Dichlorobenzene*** – Some people who drink water that contains p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.

***1,2-Dichloroethane*** – Some people who drink water that contains 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.

***Cis-1,2-Dichloroethylene*** – Some people who drink water that contains cis-1,2-dichloroethylene in excess of the MCL over many year could experience problems with their liver.

***Trans-1,2-Dichloroethylene*** – Some people who drink water that contains trans-1,2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.

***Dichloromethane*** – Some people who drink water that contains dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.

***1,2-Dichloropropane*** – Some people who drink water that contains 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.

***Ethylbenzene*** – Some people who drink water that contains ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.

***Haloacetic Acids (HAA's)*** – Some people who drink water that contains haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

***Styrene*** – Some people who drink water that contains styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.

***Tetrachloroethylene*** – Some people who drink water that contains tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.

***1,2,4-Trichlorobenzene*** – Some people who drink water that contains 1,2,4-trichlorobenzene in excess of the MCL over many years could experience changes in their adrenal glands.

***1,1,1-Trichloroethane*** – Some people who drink water that contains 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.

***1,1,2-Trichloroethane*** – Some people who drink water that contains 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.

***TTHMs [Total Trihalomethanes]*** – Some people who drink water that contains trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

***Toluene*** – Some people who drink water that contains toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.

***Vinyl Chloride*** – Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.

***Xylenes*** – Some people who drink water that contains xylenes in excess of the MCL over many years could experience damage to their nervous system.

## ***Detects of cryptosporidium.***

### ***LT2ESWTR (Long Term 2 Enhanced Surface Water Treatment Rule) (30 TAC) §290.111 (b)(4)***

#### ***BIN Category: BIN 2***

***Cryptosporidium*** – Staff constantly monitor the water supply for various constituents. CRWA detected cryptosporidium in the source water (Lake Dunlap) in 2009 and achieved a bin 2 category. A bin 2 category requires the Lake Dunlap Water Treatment Plant (WTP) to meet a 4-Log removal or inactivation of cryptosporidium. Lake Dunlap WTP has accomplished a 4-Log removal or inactivation of cryptosporidium over the complete bin 2 category duration, and continues to achieve this removal rate. It is important for you to know that cryptosporidium may cause serious illness in immune-compromised persons such as person with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders. These people should seek advice from their health care providers.

## ***Detects of radon.***

### ***Radon – ND***

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or man-made. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

## ***Violations***

Canyon Regional Water Authority Hays Caldwell Water Treatment Plant did not have any violations to report for year 2025.

## ***Contact Information:*** If you have any questions please contact:

Canyon Regional Water Authority  
Adam Telfer  
Compliance Manager  
Phone: (830) 609-0543  
Email: [adam@crwa.com](mailto:adam@crwa.com)

## ***Public Participation Opportunities:***

Board of Trustees Meeting  
Location: 850 Lakeside Pass, New Braunfels, TX 78130  
Date: Every 2<sup>nd</sup> Monday of each month unless otherwise scheduled  
Time: 6:00 PM

Information on scheduled meetings can be found on the Canyon Regional Water Authority website at <https://www.crwa.com/agendas/>.